

Certificate sponsor	Certificate number	Certificate issue date	Certificate expiry date
Laminex Group Pty Ltd 22 Trewin St Wendouree VIC 3355 Australia	FAS200378B SFC1.0	27 April 2021	30 April 2026

### Description of assessed product

The assessed product is a fire retardant treated medium density fibreboard and are proposed to be used as internal wall and ceiling lining in commercial and residential buildings.

The scope of the assessment includes the fire hazard properties of the described assessed system when tested in accordance with AS ISO 9705:2003 and classified in accordance with AS 5637.1:2015.

### Assessed product performance

The element of construction described above was assessed by this laboratory on behalf of the test sponsor in accordance with the stated classification standard in Table 1 and achieved the results outlined in Table 2. Complete description of the assessed construction can be found within the referenced assessment report.

**Table 1 Test standard and assessment report details**

Referenced report	Classification standard	Referenced report issue date	Referenced report expiry date
FAS200378 R1.0	AS 5637.1:2015	27 April 2021	30 April 2026

**Table 2 Formal assessment summary**

Product name	Core	Thickness	Laminate	Group number*	SMOGR <sub>ARC</sub> (in m <sup>2</sup> s <sup>-2</sup> × 1000)
Laminex Fireguard® Decorated MR E1 MDF	Grey solid FR MDF	9 mm – 18 mm	Melamine impregnated decorative paper	2	<100

\*Panels achieving group number 2 are assessed as group number 2-S according to the requirement of C/VM2-Verification Method: Framework for fire safety design.

### Conditions / validity

- This certificate is provided for general information only and does not comply with the regulatory requirements for evidence of compliance.
- The main assessment report must be provided for regulatory requirements and evidence of compliance.
- Reference should be made to the relevant assessment report or regulatory information report to determine the applicability of the test result to a proposed installation. Full details of the constructions and justification for the conclusions given, along with the validity statements, are given in the assessment reports.
- The results of the assessment report may be used to assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions.
- All work and services carried out by Warringtonfire Australia are subject to and conducted in accordance with our standard terms and conditions. These are available on request or at <https://www.element.com/terms/terms-and-conditions>.

<b>Testing authority</b>	Warringtonfire Australia Pty Ltd	
<b>Address</b>	Unit 2, 409-411 Hammond Road, Dandenong South, VIC 3175	
<b>Phone</b>	T: +61 (0)3 9767 1000	
<b>ABN</b>	81 050 241 524	
<b>Email</b>	info.fire.melbourne@warringtonfire.com	
<b>Authorisation</b>	Prepared by:	Reviewed by:
		
	Alim Rasel	Omar Saad