

## Formaldehyde Emission Summary

### Compact Laminate

#### REPORT NO. 14-Compact

**Company Name:**  
The Laminex Group

**Report Date:**  
25/2/2014

**Product Standard:**  
EN 438-7:2005

**Test Method:**  
EN 717-2:1994


**Specification Limits:**  
E1 =  $\leq 3.5$  mg/m<sup>2</sup>hr

Product	Result (mg/m <sup>2</sup> hr)
Alfresco Compact Laminate	0.059
Aquapanel Thin Compact Laminate	0.614
Laboratory Compact Laminate	0.095
Multipurpose Compact Laminate	0.239
XR Grade Compact Laminate	0.560

**Testing completed and traceable to the following NATA accredited laboratory**  
The Laminex Group Technology Centre. NATA accreditation number 15305

Emission values stated are specific for the sample tested.

Authority:

  
Josh Smolenaers  
Laboratory Manager