

# Emission Test Certificate

Friday, September 19<sup>th</sup>, 2014

Supplier: The Laminex Group (22 Trewin St, Wendouree, VIC 3355)

Sample Description: Decorated E0 Particleboard (Reference: 15573)

Date Tested: September 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p><b>Green Building Council of Australia</b></p> <p><b>Green Star Office Interiors v1.1 IEQ-11</b></p>	<p><b>Decorated E0 Particleboard</b></p>
<p>Total Volatile Organic Compound Emission Rate limit &lt;0.5mg/m<sup>2</sup>/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.198mg/m<sup>2</sup>/hr</p>

*The above results can be considered representative of the Laminex Vertiboard E0, Formica Colourpanel E0 and Trade Essentials Whiteboard E0 products.*



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant

CV140901