

Emission Test Certificate

Thursday, October 9th, 2014

Supplier: The Laminex Group (22 Trewin St, Wendouree, VIC 3355)

Sample Description: High Pressure Laminate (Reference: 15703)

Date Tested: September 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p align="center">Green Building Council of Australia Green Star Office Interiors v1.1 IEQ-11</p>	<p align="center">High Pressure Laminate</p>
<p align="center">Total Volatile Organic Compound Emission Rate limit <0.5mg/m²/hr</p>	<p align="center">Total Volatile Organic Compound Emission Rate: <0.009mg/m²/hr</p>

The above results can be considered representative of the Laminex Redback, Laminex Squareform, Laminex DiamondGloss, Laminex Fusion, Laminex Innovations, Laminex 180fx, Formica AR+, Formica Europa and Formica Decorative Laminate products.



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV140901