

# Emission Test Certificate

Thursday, October 9<sup>th</sup>, 2014

Supplier: The Laminex Group (22 Trewin St, Wendouree, VIC 3355)

Sample Description: STD/MR E1 Particleboard (Reference: 15582)

Date Tested: September 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<b>Green Building Council of Australia Green Star Office Interiors v1.1 IEQ-11</b>	<b>STD/MR E1 Particleboard</b>
Total Volatile Organic Compound Emission Rate limit <0.5mg/m <sup>2</sup> /hr	Total Volatile Organic Compound Emission Rate: 0.126mg/m <sup>2</sup> /hr

*The above results can be considered representative of the Trade Essentials Particleboard and Trade Essentials Particleboard MR products.*



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant

CV140901