

# Emission Test Certificate

Monday 15<sup>th</sup> June 2020

Supplier: The Laminex Group Technology Centre (22 Trewin Street, Wendouree, 3355, VIC)

Sample Description: Laminex Laboratory Grade Compact Laminate

Date Tested: June 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hrs):

<p align="center"><b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3 - 13.1.2B &amp; 13.2</b> <b>Green Star Interiors V1.3 - 12.1.2B</b></p>	<p align="center"><b>Laminex Laboratory Grade Compact Laminate</b></p>
<p align="center">Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m<sup>2</sup>/hr</p>	<p align="center">Total Volatile Organic Compound Emission Rate: 0.021 mg/m<sup>2</sup>/hr</p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Travis Hale  
BSc (Biotechnology)  
Consultant



Tuan Duong  
B.Eng. (Chemical)  
Consultant

V2006009