

Emission Test Certificate

Wednesday, February 4th, 2015

Supplier: The Laminex Group (22 Trewin St, Wendouree, VIC 3355)

Sample Description: Formica Laminate Flooring

Date Tested: December 2014 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p>Green Building Council of Australia</p> <p>Green Star Office Design v3 IEQ-13</p>	<p>Formica Laminate Flooring</p>
<p>Total Volatile Organic Compound Emission Rate limit <0.5mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.084mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV141204