

# Emission Test Certificate

Friday, June 28, 2013

Supplier: The Laminex Group (22 Trewin St, Wendouree, VIC 3355)

Sample Description: Formica Magnetic Metallic HPL

Date Tested: May 2013 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<b>Green Building Council of Australia Green Star Office Interiors v1.1 IEQ-11</b>	<b>Formica Magnetic Metallic HPL</b>
Total Volatile Organic Compound Emission Rate limit $<0.5\text{mg}/\text{m}^2/\text{hr}$	Total Volatile Organic Compound Emission Rate: $0.024\text{mg}/\text{m}^2/\text{hr}$



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Nick Joy  
BSc(Hons)  
Consultant

CV130520