

## **Emission Test Certificate**

Monday, July 4<sup>th</sup>, 2011

Supplier: The Laminex Group (21 Trewin Street, Wendouree Victoria 3355)

Sample Description: Laminex Litecraft

Date Tested: June 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

**Emission Data:** 

## **Laminex Litecraft**

Total Volatile Organic Compound Emission Rate: <0.002 mg/m<sup>2</sup>/hr (7 days)

When this product is used in the typical manner in an office building the resulting airborne total volatile organic compound concentration can be expected to be less than 0.5 mg/m³ as specified by Green Building Council of Australia Green Star Office Interiors IEQ-11.

Dr. Vyt Garnys

PhD, BSc(Hons) AIMM, ARACI, ISIAQ

ACA, AIRAH, FMA

Managing Director and Principal Consultant

Project CV110603