

# Emission Test Certificate

Saturday, 18<sup>th</sup> December 2010

Supplier: The Laminex Group (21 Trewin Street, Wendouree Victoria 3355)

Sample Description: 12 mm Strandboard

Date Tested: December 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

## 12 mm Strandboard

Total Volatile Organic Compound Emission Rate: 0.03 mg/m<sup>2</sup>/hr (7 days)

When this product is used in the typical manner in an office building the resulting airborne total volatile organic compound concentration can be expected to be less than 0.5 mg/m<sup>3</sup> as specified by Green Building Council of Australia Green Star Office Interiors IEQ-11.



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

**Project CV101127**