

Emission Test Certificate

Monday, September 24, 2012

Supplier: The Laminex Group (21 Trewin St, Wendouree, VIC 3355)

Sample Description: White PVC Foam Sheet, Item 958385

Date Tested: September 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p>Green Building Council of Australia Green Star Office Design IEQ-13</p>	<p>White PVC Foam Sheet, Item # 958385</p>
<p>Total Volatile Organic Compound Emission Rate limit <math><0.5\text{mg}/\text{m}^2/\text{hr}</math></p>	<p>Total Volatile Organic Compound Emission Rate: <math><0.01\text{mg}/\text{m}^2/\text{hr}</math></p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc(Biotechnology)
Consultant

CV120906