

NATA Accredited Laboratory

Accreditation No: 15305



a division of Laminex Group Pty Ltd ABN 98 004 093 092

Accredited for compliance with ISO/IEC 17025 - Testing

The Laminex Group Technology Centre

Postal Address: PO BOX 720, Wendouree, Vic 3355 Address: 22 Trewin St, Wendouree, Vic 3355 Telephone: (03) 5337 3673 Fax: (03) 5337 3647

Test Report No. 2432226

Date of Issue 20/05/2024

Client: Chad McKelvie

Laminex Australia
Technical Solutions

This test report shall not be reproduced, except in full, without written approval from The Laminex Group Technology Centre

The material contained is this report is confidential to the entity identified as 'Client' above.

As the sample(s) have been provided by the cleint, the results contained in this report apply only to the sample(s) as received.

Document Number: F-5.10.1.00 Issued by: Research Development Technician

Test Report No.

2432226

Date of Issue:

20/05/2024

Laminex Sample Reference No.	32226
Client Sample Reference No.	2400615
Product Description:	22mm Particleboard Flooring
(Supplied by client)	General Purpose, Class 1, E1
Surface Treatment	None (Raw)
Receive Date:	25/01/2024
Condition:	
Testing Performed Date(s):	30/01/24 - 07/02/24
Specification Standard	AS/NZS 1860.1:2017
Product Classification	Class 1, E1 Particleboard Flooring

			Re	sult	Product	Limit	
Toot	Method	115.14	Maan	Ctd Day	Limit Value	Standard	Compliance
Test	Method	Unit	Mean	Std Dev	Limit Value	Clause	Compliance
	AS/NZS 4266.1 2017				Maximum	Clause 6.1	
Formaldehyde Emission	Section 17	mg/L	1.18	0	1.5 (E1)	table 1	PASS E1

Fomraldehyde Emission Class: E1

Co	m	m	e	n	t	•

As agreed to by the client, compliance to product limits is based solely on the reported test result (s) and no uncertainty of measurement shall be taken into account.

Approved Signatory:

Laboratory Supervisor (K.Coull) Could

Test Report No.

2432226

Date of Issue:

20/05/2024

Laminex Sample Reference No.	31936
Client Sample Reference No.	2328601
Product Description: (Supplied by client)	19mm Particleboard Flooring General Purpose, Class 1, E1
Surface Treatment	None (Raw)
Receive Date:	7/11/2023
Condition:	Good
Testing Performed Date(s):	13/11/23 - 21/11/23
Specification Standard	AS/NZS 1860.1:2017
Product Classification	Class 1, E1 Particleboard Flooring

			Re	sult	Product	Limit	
Test	Method	Unit	Mean	Std Dev	Limit Value	Standard Clause	Compliance
	AS/NZS 4266.1 2017				Maximum	Clause 6.1	
Formaldehyde Emission	Section 17	mg/L	1.32	0.07	1.5 (E1)	table 1	PASS E1

Fomraldehyde Emission Class: E1

As agreed to by the client, compliance to product limits is based solely on the reported test result (s) and no uncertainty of measurement shall be taken into account.

Approved Signatory:

Laboratory Supervisor (K.Coull) Could

Document Number: F-5.10.1.00 Issued by: Research Development Technician

Test Report No.

2432226

Date of Issue:

20/05/2024

Product Classification	Class 1, E1 Particleboard Flooring
Specification Standard	AS/NZS 1860.1:2017
Testing Performed Date(s):	4/10/23 - 12/10/23
Condition:	Good
Receive Date:	15/09/2023
Surface Treatment	None (Raw)
Product Description: (Supplied by client)	22mm Particleboard Flooring Termite Treated, Class 1, E1
Client Sample Reference No.	2322034
Laminex Sample Reference No.	31680

			Re	sult	Product	Limit	
Test	Method	Unit	Mean	Std Dev	Limit Value	Standard Clause	Compliance
	AS/NZS 4266.1 2017				Maximum	Clause 6.1	
Formaldehyde Emission	Section 17	mg/L	0.99	0.03	1.5 (E1)	table 1	PASS E1

Fomraldehyde Emission Class: E1

Comments

As agreed to by the client, compliance to product limits is based solely on the reported test result (s) and no uncertainty of measurement shall be taken into account.

Approved Signatory:

Laboratory Supervisor (K.Coull)

Document Number: F-5.10.1.00

Issued by: Research Development Technician

Test Report No. 2432226 Date of Issue: 20/05/2024

Laminex Sample Reference No.	31937
Client Sample Reference No.	2327612
Product Description: (Supplied by client)	19mm Particleboard Flooring Termite Treated, Class 1, E1
Surface Treatment	None (Raw)
Receive Date:	7/11/2023
Condition:	Good
Testing Performed Date(s):	14/11/23 - 22/11/23
Specification Standard	AS/NZS 1860.1:2017
Product Classification	Class 1, E1 Particleboard Flooring

			Re	esult	Product	Limit	
Test	Method	Unit	Mean	Std Dev	Limit Value	Standard Clause	Compliance
	AS/NZS 4266.1 2017				Maximum	Clause 6.1	
Formaldehyde Emission	Section 17	mg/L	1.28	0.01	1.5 (E1)	table 1	PASS E1

Fomraldehyde Emission Class: E1

Co	m	m	Δ	n	ŕ
Vυ	ш	ш	c	ш	ι

As agreed to by the client, compliance to product limits is based solely on the reported test result (s) and no uncertainty of measurement shall be taken into account.

Approved Signatory:

Laboratory Supervisor (K.Coull) # Could