

Emission Test Certificate

Thursday, May 24th, 2012

Supplier: The Laminex Group (21 Trewin St, Wendouree, VIC 3355)

Sample Description: 13mm Laminex Alfresco Exterior Grade Compact Laminate

Date Tested: May 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Green Building Council of Australia Green Star Office Interiors IEQ-11	13mm Laminex Alfresco Exterior Grade Compact Laminate
Total Volatile Organic Compound Emission Rate limit <math><0.5\text{mg}/\text{m}^2/\text{hr}</math>	Total Volatile Organic Compound Emission Rate: <math><0.196\text{ mg}/\text{m}^2/\text{hr}</math> (24 hours)



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Anne Saletti
BNanotech/BSc(Hons)
Consultant

CV120428